



220121130035



中国认可
国际互认
检测
TESTING
CNAS L6635

编号 S/N: (京) 雷检字[2025]第 (L0441) 号

型式试验报告

Type Test Report

样品名称:

Sample name:

低压配电系统的电涌保护器

型号规格:

Model:

RDU5-A25/420V/1P.2P.3P.4P

受检单位:

Applicant:

人民电器集团有限公司

检测类别:

Type of test:

型式试验

报告签发日期:

Date of issue:

2025 年 04 月 22 日

北京市雷闪防雷设施检测服务中心

Beijing Leishan Testing Service Center of Lightning Protection Facilities

检测专用章

中心声明

Statement

1. 本检测报告无“检测专用章”无效。

The test report is invalid without the appropriate stamp of the test department on it.

2. 本检测报告无检测、审核、批准人签字无效。

The test report is invalid without sign.

3. 本检测报告涂改、增删无效。

Duplication of test report is invalid.

4. 未经本中心书面授权，不得部分复制（全部复制除外）本报告。

Without the written authorization of the center, part of the copy is prohibited (except copy all pages).

5. 本检测报告仅对来样产品所测试的项目负责。

Test report is only valid for the items tested by the sample products.

6. 委托方对本报告若有异议，请于收到报告之日起十五日内向本中心书面申请复议，逾期不予受理。

If the client has any objection to this report, please submit a written application for reconsideration within fifteen days from the date of receipt of the report.

7. 请委托方自本报告签发日起 **24 个月** 后或产品设计、材料、工艺等出现重大改动时，请及时申请监督复测或重新检测。

24 months after the date of issue of this report, or if product change in design, material and process, the client must apply for surveillance test or re-inspection in time.

编制说明

Compilation of instructions

1. 本报告使用科学计数法保留三位有效数字或二位小数，标准中特定的参数数据除外。

The test report used scientific notation method to retain three significance digit or two decimal , except for specific parameter data in the standard.

2. 本报告采用数据修约规则，参考 GB/T8170-2008《数值修约规则与极限数值的表示和判定》

The data uses rules for rounding , and determining the reference <GB/T8170-2008 Rules of rounding off for numerical values & expression and judgement of limiting values>.

3. 实验数据单位除执行测试标准外，参照国际单位制基本单位 SI 与国标《GB_3102.5-1993》。

The experimental data units refer to the SI and the national standard <GB_3102.5-1993> in addition to executing the test standard.

4. 实验数据误差分析采用《CTL-DSH-251B-2009 测量仪器精度误差国际决议表》中的范围要求。

The error analysis adopts the scope requirements of the <CTL-DECISION SHEET-251B-2009>.



扫描左边二维码，快速进行报告信息查询或者登陆官网查询。

查询密码详见报告中的《网上查询说明》。

Scan the QR code on the left to quickly query the report information or log on to the official website.

Please refer to "online query instructions" in the report for the query password.

中心地址 ADD: 北京市昌平区振兴路 2 号中国气象科技园 4 号楼一、二层

Ground floor Building 4, China Meteorological Bureau Science Park, No.2, Zhenxing Road, Changping District, Beijing, China.

联系电话 TEL: 010-68409130

邮政编码 Post code: 102299

电子邮箱 E-mail: bjleishan@163.com



检验检测机构 资质认定证书

证书编号: 220121130035

名称: 北京市雷闪防雷设施检测服务中心

地址: 北京市昌平区振兴路2号中国气象科技园4号楼一、二层

经审查,你机构已具备国家有关法律、行政法规规定的基
本条件和能力,现予批准,可以向社会出具具有证明作用的数
据和结果,特发此证。资质认定包括检验检测机构计量认证。

检验检测能力及授权签字人见证书附表

许可使用标志



220121130035



101-012-022
AAB-189-B32

发证日期: 2022年10月11日

有效期至: 2028年10月10日

发证机关: 北京市市场监督管理局



本证书由国家认证认可监督管理委员会监制,在中华人民共和国境内有效。

扫描二维码或登录发证机关政府网站验证

Certificate of Appointment

No. UA 50670617-0001

The Applicant

**Beijing Leishan Testing Service Center
of Lightning Protection Facilities
Ground and Second floor Building 4,
China Meteorological Bureau Science Park, No.2, Zhenxing Road,
Changping District
Beijing
P.R. China**

has been authorized to carry out testing by the order
and under supervision of TÜV Rheinland
according to

IEC 61643-11:2011; EN 61643-11:2012+A11; IEC 61643-31:2018;
IEC 61643-21:2000+A1:2008+A2:2012; IEC 62561-1:2017; GB/T 21698-2022;
EN 61643-21:2001+A2:2013; IEC 62561-2:2018; IEC 62561-3:2017;
IEC 62561-4:2017; IEC 62561-5:2017; IEC 62561-6:2018;
IEC 62561-7:2018; 2PFG2634/08.17; NFC17-102-2011;

An audit of the laboratory was conducted according to the applicable clauses of
ISO/IEC 17025 by a TÜV Rheinland auditor.

Audit Report No. CN255R9I - 001

This certificate is valid from 26 March 2025 until 25 March 2026.

Date of issue: 26 March 2025

TÜV Rheinland (China) Ltd.

3F and 12F, Building 4, No. 15, Ronghua South Road
Beijing Economic Technological Development Area
Beijing, P.R. China.

Tel: +86 10 8524 2222

Fax.: +86 10 8524 2200

<http://www.chn.tuv.com>



Certification Body

Yang Yongming

Yongming Yang

型式试验报告

TYPE TEST REPORT

样品名称: 低压配电系统的电涌保护器

Sample name:

型号: RDU5-A25/420V/1P. 2P. 3P. 4P

Model:

品牌:

(Logo):

PEOPLE

数量: 14

Quantity:

收样日期: 2025/03/27

Receiving Date:

检测日期: 2025/03/28-2025/04/22

Testing Date:

申请人: 人民电器集团有限公司

Applicant:

申请人地址: 乐清市经济开发区(柳市人民工业园)

Address:

制造商: 人民电器集团有限公司

Manufacturer:

制造商地址: 乐清市经济开发区(柳市人民工业园)

Address:

生产厂: 人民电器集团有限公司

Production:

生产厂地址: 乐清市经济开发区(柳市人民工业园)

Address:

试验依据标准: GB/T 18802.11-2020《低压电涌保护器(SPD) 第11部分 低压电源系统的电涌保护器性能要求和试验方法》

Standard: Low-voltage surge protective devices(SPD) - Part 11: Surge protective devices connected to low-voltage power systems - Requirements and test methods GB/T18802.11-2020/IEC 61643-11:2011,MOD

试验结论 Test conclusion: 合格 PASS

检测人: 廉金彪 赵丰炳

Tested by

审核人: 肖行

Reviewed by

批准人: 孙涌

Approved by

(检测专用章)

(Testing Stamp)

2025年04月22日

备注 Remarks:

下次监督日期 the next surveillance test: 2027年04月21日

或按声明第7条执行 Carry out 7th of Statement.

型号: RDU5-A25/420V/1P. 2P. 3P. 4P